


FIRE FACT NO. 040 CHECKLIST(s): 99

TITLE : FIRE SEPARATION OF HAZARDOUS ROOMS

CHECKLIST ITEM(s) : 99-44, 45, 46, 47

REFERENCE(s) : 91-101/6-4.1.1

PAGE 1 of 1



*** 1 HOUR FIRE RESISTIVE SEPARATION MUST ALSO INCLUDE THE WALLS, CEILING AND FLOOR OF THE PROTECTED ROOM.**

